



Ganesh Consultancy & Analytical Services

(An ISO 9001 - 2008, ISO 14001-2004 Certified Laboratory : Approved by Agmark - Govt. of India, Empanelled by - KSPCB)



ISO-9001:2008
ISO-14001:2004
Reg. No. RI 91/1115

Test House : 294A, Hebbal Industrial Area, Mysore - 570 016 ☎ - 2402986 **Telefax** - 4282027
Office : 1030, Geetha Road, Chamarajapuram, Mysore - 570 005 • **Phone** : 2402987
Bangalore Office : # 1/C, Anjaneya Temple Street 3rd Cross, Yadiyur, Bangalore - 560 082
Phone : 080-26766600, 9845475436 • **Web** : www.ganeshlaboratory.com
Email : lab.ganesh@gmail.com, ganeshlab@yahoo.com



TEST REPORT

CUSTOMER ADDRESS,
The Project Officer,
M/s. Centre for Environment Education
Gulbarga Field Office, 2nd Floor, HKADB Premises
Aiwan-E-Shahi
GULBARGA - 585 102.

Page 1 of 1

Control No. GC:388/2013-14
CUSTOMER REF:
CEE/JO/245/2012-13, Dt. 01-03-2013
Sample Receipt Date: 19-04-2013
Date of Commencing: 22-04-2013
Date of Completion: 27-04-2013
Date of Report: 29-04-2013

- 1) Description of Sample: Effluent Water.
- 2) Sample Marked as: Treated
- 3) Sample Package - Plastic Bottle.
- 4) Condition of Sample: Good
- 5) Date of Sampling: 19-04-2013
- 6) CHEMICAL ANALYSIS.

- 7) Customer Code: NA
- 8) Sampled By: - Lab Personnel
- 9) Sampling Protocol: IS: 3025

Sl. No.	Parameters	Units	Results	KSPCB Limits
1	p ^H Value	---	7.42	6.00-8.50
2	Total Suspended Solids	mg/l	36	100 max
3	Oil & Grease	mg/l	<2.0	10 max
4	Chemical Oxygen Demand	mg/l	198	250 max
5	Biochemical Oxygen Demand	mg/l	28	30 max
6	Bio-assay Test	---	96% Survival of fish after 96 Hours in 100% effluent	90% survival of fish after 96 Hours in 100% effluent

Shimshatedul
Authorised Signatory

For GANESH CONSULTANCY & ANALYTICAL SERVICES